



IES INDOOR REPORT

PHOTOMETRIC FILENAME : PBL G2 4 HI UV FR 850.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001249-010A(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 3/18/2020

[MANUFAC] Lumen Focus, LLC

[LUMCAT] PBL G2 4 HI UV FR 850

[LUMINAIRE] Surface/pendant mounted, formed white enamel aluminum housing/reflectors,

[MORE] frosted plastic enclosures below LEDs.

[LAMP] 448 white LEDs, four 20103 5000K 3437A1 LED boards with 112 LEDs

[MORE] each.

[BALLAST] Two ULT Everline D21CC80UNVPW-C LED drivers each programmed at 1460mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	22799
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	160
Total Luminaire Watts	142.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.79 ft
Luminous Width (90-270)	0.92 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	22290	23570	24482
55	19564	22724	24282
65	16006	21846	23672
75	12079	19081	15072
85	7809	14063	10888

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4 HI UV FR 850.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	2975.3	N.A.	13.00
0-30	6315.35	N.A.	27.70
0-40	10332.59	N.A.	45.30
0-60	18163.85	N.A.	79.70
0-80	22412.25	N.A.	98.30
0-90	22796.11	N.A.	100.00
10-90	22025.76	N.A.	96.60
20-40	7357.29	N.A.	32.30
20-50	11493.55	N.A.	50.40
40-70	10629.27	N.A.	46.60
60-80	4248.4	N.A.	18.60
70-80	1450.39	N.A.	6.40
80-90	383.85	N.A.	1.70
90-110	3.33	N.A.	0.00
90-120	3.33	N.A.	0.00
90-130	3.33	N.A.	0.00
90-150	3.33	N.A.	0.00
90-180	3.33	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	22799.44	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	770.34
10-20	2204.96
20-30	3340.05
30-40	4017.24
40-50	4136.26
50-60	3695.00
60-70	2798.01
70-80	1450.39
80-90	383.85
90-100	3.11
100-110	0.22
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4 HI UV FR 850.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	76	82	78	74	79	75	72	70
3	90	80	72	65	88	78	71	65	75	69	63	72	67	62	70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54	65	58	53	62	57	53	50
5	76	63	54	48	74	62	54	47	60	52	47	58	51	46	56	50	46	44
6	70	57	48	41	68	56	47	41	54	47	41	52	46	41	51	45	40	38
7	65	52	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34
8	61	47	39	33	59	46	38	33	45	38	32	44	37	32	43	36	32	30
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	31	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4 HI UV FR 850.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	22.2	23.8	22.6	24.1	24.5	23.6	25.3	24.0	25.6	25.9
	3H	23.7	25.2	24.1	25.5	25.9	25.4	26.9	25.8	27.2	27.6
	4H	24.2	25.6	24.6	25.9	26.3	25.8	27.2	26.2	27.6	27.9
	6H	24.5	25.8	24.9	26.2	26.6	26.1	27.4	26.5	27.7	28.1
	8H	24.6	25.9	25.1	26.2	26.6	26.2	27.4	26.6	27.8	28.2
	12H	24.7	25.9	25.1	26.2	26.7	26.2	27.4	26.6	27.8	28.2
4H	2H	23.1	24.5	23.5	24.8	25.2	24.2	25.6	24.6	25.9	26.3
	3H	24.8	26.0	25.3	26.4	26.8	26.2	27.4	26.6	27.8	28.2
	4H	25.5	26.5	25.9	26.9	27.4	26.7	27.8	27.2	28.2	28.6
	6H	25.9	26.9	26.4	27.3	27.8	27.1	28.0	27.5	28.4	28.9
	8H	26.1	26.9	26.6	27.4	27.9	27.2	28.1	27.7	28.5	29.0
	12H	26.2	26.9	26.7	27.4	27.9	27.3	28.0	27.8	28.5	29.0
8H	4H	25.9	26.8	26.4	27.2	27.7	27.0	27.9	27.5	28.3	28.8
	6H	26.5	27.2	27.0	27.7	28.2	27.4	28.2	27.9	28.7	29.1
	8H	26.8	27.4	27.3	27.9	28.4	27.6	28.3	28.1	28.8	29.2
	12H	26.9	27.5	27.4	28.0	28.5	27.8	28.3	28.3	28.8	29.4
12H	4H	26.0	26.7	26.4	27.2	27.7	27.0	27.8	27.5	28.3	28.7
	6H	26.6	27.3	27.1	27.7	28.3	27.5	28.2	28.0	28.6	29.2
	8H	26.9	27.5	27.4	27.9	28.5	27.7	28.3	28.2	28.8	29.3

Maximum UGR = 29.4

POLAR GRAPH



Maximum Candela = 8177.598 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)