



IES INDOOR REPORT

PHOTOMETRIC FILENAME : PBL G2 4W LW HE UV 840.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001249-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 3/24/2020

[MANUFAC] Lumen Focus, LLC

[LUMCAT] PBL G2 4W LW HE UV 840

[LUMINAIRE] Surface/pendant mounted, formed white enamel aluminum housing/reflectors,

[MORE] no enclosure.

[LAMP] 896 white LEDs, eight 20103 4000K 3437A1 LED boards with 112 LEDs each.

[BALLAST] Two ULT Everline D28CC95UVP12-F LED drivers each programmed to 1900mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	32352
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	179
Total Luminaire Watts	180.7
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.79 ft
Luminous Width (90-270)	1.25 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	24800	24556	24678
55	24126	24010	24292
65	22464	22743	23491
75	18874	20863	16088
85	9644	6457	7111

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW HE UV 840.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	4037.86	N.A.	12.50
0-30	8624.37	N.A.	26.70
0-40	14235.38	N.A.	44.00
0-60	25580.07	N.A.	79.10
0-80	31964.48	N.A.	98.80
0-90	32347.93	N.A.	100.00
10-90	31306.51	N.A.	96.80
20-40	10197.52	N.A.	31.50
20-50	16113.44	N.A.	49.80
40-70	15547.24	N.A.	48.10
60-80	6384.41	N.A.	19.70
70-80	2181.87	N.A.	6.70
80-90	383.44	N.A.	1.20
90-110	3.98	N.A.	0.00
90-120	3.98	N.A.	0.00
90-130	3.98	N.A.	0.00
90-150	3.98	N.A.	0.00
90-180	3.98	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	32351.91	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	1041.42
10-20	2996.44
20-30	4586.52
30-40	5611.00
40-50	5915.92
50-60	5428.77
60-70	4202.54
70-80	2181.87
80-90	383.44
90-100	3.96
100-110	0.02
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW HE UV 840.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	79	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	73	61	53	47	59	52	46	57	51	46	55	50	45	43
6	70	56	47	41	68	55	47	41	53	46	40	52	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	49	41	35	47	40	35	46	40	35	33
8	60	46	38	32	58	46	38	32	44	37	32	43	36	31	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	28	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW HE UV 840.IES

UGR TABLE - CORRECTED


Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	23.3	24.9	23.6	25.2	25.5	23.5	25.1	23.8	25.4	25.7
	3H	25.1	26.6	25.5	26.9	27.3	25.4	26.9	25.8	27.3	27.6
	4H	25.7	27.1	26.1	27.5	27.8	25.8	27.2	26.2	27.6	28.0
	6H	26.1	27.4	26.5	27.8	28.2	25.9	27.3	26.4	27.6	28.0
	8H	26.3	27.5	26.7	27.9	28.3	26.0	27.2	26.4	27.6	28.0
	12H	26.3	27.5	26.7	27.9	28.3	26.0	27.2	26.4	27.5	28.0
4H	2H	23.9	25.3	24.3	25.7	26.1	24.1	25.5	24.5	25.8	26.2
	3H	26.0	27.1	26.4	27.5	27.9	26.3	27.5	26.7	27.9	28.3
	4H	26.7	27.8	27.2	28.2	28.6	26.8	27.9	27.2	28.3	28.7
	6H	27.3	28.2	27.7	28.6	29.1	27.0	27.9	27.4	28.3	28.8
	8H	27.4	28.3	27.9	28.7	29.2	27.0	27.9	27.4	28.3	28.8
	12H	27.5	28.3	28.0	28.7	29.2	27.0	27.8	27.5	28.3	28.7
8H	4H	27.0	27.9	27.5	28.3	28.8	27.1	27.9	27.5	28.4	28.8
	6H	27.7	28.4	28.1	28.9	29.3	27.3	28.0	27.8	28.5	29.0
	8H	27.9	28.5	28.4	29.0	29.5	27.3	28.0	27.8	28.5	29.0
	12H	28.0	28.5	28.5	29.0	29.6	27.4	27.9	27.9	28.4	29.0
12H	4H	27.0	27.8	27.5	28.3	28.7	27.1	27.9	27.6	28.3	28.8
	6H	27.7	28.3	28.2	28.8	29.3	27.3	28.0	27.8	28.4	29.0
	8H	27.9	28.5	28.4	29.0	29.5	27.4	27.9	27.9	28.4	29.0

Maximum UGR = 29.6

POLAR GRAPH



Maximum Candela = 11064.646 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)