



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : PBL G2 4W LW UV 850.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001249-018(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 3/24/2020

[MANUFAC] Lumen Focus, LLC

[LUMCAT] PBL G2 4W LW UV 850

[LUMINAIRE] Surface/pendant mounted, formed white enamel aluminum housing/reflectors,

[MORE] no enclosure.

[LAMP] 672 white LEDs, six 20103 5000K 3437A1 LED boards with 112 LEDs each.

[BALLAST] Two ULT Everline D28CC95UVPA12-F LED drivers each programmed to 1950mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	32609
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	174
Total Luminaire Watts	187.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.30
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.79 ft
Luminous Width (90-270)	1.25 ft
Luminous Height	0.00 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	24997	24751	24874
55	24317	24201	24485
65	22643	22923	23678
75	19023	21029	16216
85	9720	6509	7168

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL G2 4W LW UV 850.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	4069.92	N.A.	12.50
0-30	8692.85	N.A.	26.70
0-40	14348.41	N.A.	44.00
0-60	25783.19	N.A.	79.10
0-80	32218.3	N.A.	98.80
0-90	32604.78	N.A.	100.00
10-90	31555.09	N.A.	96.80
20-40	10278.49	N.A.	31.50
20-50	16241.39	N.A.	49.80
40-70	15670.69	N.A.	48.10
60-80	6435.11	N.A.	19.70
70-80	2199.2	N.A.	6.70
80-90	386.49	N.A.	1.20
90-110	4.01	N.A.	0.00
90-120	4.01	N.A.	0.00
90-130	4.01	N.A.	0.00
90-150	4.01	N.A.	0.00
90-180	4.01	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	32608.79	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	1049.69
10-20	3020.23
20-30	4622.94
30-40	5655.56
40-50	5962.9
50-60	5471.88
60-70	4235.91
70-80	2199.2
80-90	386.49
90-100	3.99
100-110	0.02
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL G2 4W LW UV 850.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	79	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	73	61	53	47	59	52	46	57	51	46	55	50	45	43
6	70	56	47	41	68	55	47	41	53	46	40	52	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	49	41	35	47	40	35	46	40	35	33
8	60	46	38	32	58	46	38	32	44	37	32	43	36	31	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	28	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : PBL G2 4W LW UV 850.IES**

**UGR TABLE - CORRECTED**

Reflectances


Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	23.3	24.9	23.6	25.2	25.5	23.5	25.1	23.8	25.4	25.7
	3H	25.1	26.6	25.5	26.9	27.3	25.4	26.9	25.8	27.3	27.6
	4H	25.7	27.1	26.1	27.5	27.8	25.8	27.2	26.2	27.6	28.0
	6H	26.1	27.4	26.5	27.8	28.2	25.9	27.3	26.4	27.6	28.0
	8H	26.3	27.5	26.7	27.9	28.3	26.0	27.2	26.4	27.6	28.0
	12H	26.3	27.5	26.7	27.9	28.3	26.0	27.2	26.4	27.5	28.0
4H	2H	23.9	25.3	24.3	25.7	26.1	24.1	25.5	24.5	25.8	26.2
	3H	26.0	27.1	26.4	27.5	27.9	26.3	27.5	26.7	27.9	28.3
	4H	26.7	27.8	27.2	28.2	28.6	26.8	27.9	27.2	28.3	28.7
	6H	27.3	28.2	27.7	28.6	29.1	27.0	27.9	27.4	28.3	28.8
	8H	27.4	28.3	27.9	28.7	29.2	27.0	27.9	27.4	28.3	28.8
	12H	27.5	28.3	28.0	28.7	29.2	27.0	27.8	27.5	28.3	28.7
8H	4H	27.0	27.9	27.5	28.3	28.8	27.1	27.9	27.5	28.4	28.8
	6H	27.7	28.4	28.1	28.9	29.3	27.3	28.0	27.8	28.5	29.0
	8H	27.9	28.5	28.4	29.0	29.5	27.3	28.0	27.8	28.5	29.0
	12H	28.0	28.5	28.5	29.0	29.6	27.4	27.9	27.9	28.4	29.0
12H	4H	27.0	27.8	27.5	28.3	28.7	27.1	27.9	27.6	28.3	28.8
	6H	27.7	28.3	28.2	28.8	29.3	27.3	28.0	27.8	28.4	29.0
	8H	27.9	28.5	28.4	29.0	29.5	27.4	27.9	27.9	28.4	29.0

Maximum UGR = 29.6

POLAR GRAPH



Maximum Candela = 11152.505 Located At Horizontal Angle = 90, Vertical Angle = .5  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)