



IES INDOOR REPORT

PHOTOMETRIC FILENAME : PBL G2 4W LW UV FR 835.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] LLIA001249-017(s)

[TESTLAB] LightLab International Allentown, LLC

[ISSUE DATE] 3/24/2020

[MANUFAC] Lumen Focus, LLC

[LUMCAT] PBL G2 4W LW UV FR 835

[LUMINAIRE] Surface/pendant mounted, formed white enamel aluminum housing/reflectors

[MORE] frosted plastic enclosures below LEDs.

[LAMP] 672 white LEDs, six 20103 3500K 3437A1 LED boards with 112 LEDs each.

[BALLAST] Two ULT Everline D28CC95UVPA12-F LED drivers each programmed to 1950mA

[OTHER] 120.0Vac, 60.00Hz

[OTHER] This test was performed using the absolute method of photometry.

[MORE] Lamp lumens value was set to -1

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	29595
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	158
Total Luminaire Watts	187.4
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.79 ft
Luminous Width (90-270)	1.25 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	20765	22087	23000
55	18145	21212	22835
65	14755	20352	22930
75	11096	20124	19028
85	7306	15472	14244

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW UV FR 835.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	3812.6	N.A.	12.90
0-30	8092.88	N.A.	27.30
0-40	13235.01	N.A.	44.70
0-60	23228.58	N.A.	78.50
0-80	28951.56	N.A.	97.80
0-90	29575.7	N.A.	99.90
10-90	28588.97	N.A.	96.60
20-40	9422.41	N.A.	31.80
20-50	14705.4	N.A.	49.70
40-70	13606.79	N.A.	46.00
60-80	5722.98	N.A.	19.30
70-80	2109.75	N.A.	7.10
80-90	624.15	N.A.	2.10
90-110	18.88	N.A.	0.10
90-120	18.88	N.A.	0.10
90-130	18.88	N.A.	0.10
90-150	18.88	N.A.	0.10
90-180	18.88	N.A.	0.10
110-180	0.00	N.A.	0.00
0-180	29594.58	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	986.74
10-20	2825.86
20-30	4280.27
30-40	5142.14
40-50	5282.99
50-60	4710.57
60-70	3613.23
70-80	2109.75
80-90	624.15
90-100	18.79
100-110	0.10
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW UV FR 835.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	98	94	97	94	91	93	91	88	90	87	85	83
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	72	69
3	90	79	71	64	87	78	70	64	75	68	63	72	66	62	69	65	61	58
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	59	52	46	57	51	46	56	50	45	43
6	70	56	47	41	68	55	47	41	54	46	40	52	45	40	50	44	40	38
7	65	51	42	36	63	50	42	36	49	41	36	47	41	35	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	33	29	39	33	28	27
10	53	40	32	26	52	39	31	26	38	31	26	37	31	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : PBL G2 4W LW UV FR 835.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	21.8	23.5	22.2	23.8	24.1	23.3	25.0	23.7	25.3	25.6
	3H	23.3	24.8	23.7	25.1	25.5	25.5	26.9	25.8	27.3	27.6
	4H	23.8	25.2	24.2	25.6	25.9	26.1	27.5	26.5	27.9	28.3
	6H	24.1	25.5	24.6	25.8	26.2	26.6	27.9	27.0	28.2	28.6
	8H	24.2	25.5	24.7	25.9	26.3	26.7	27.9	27.1	28.3	28.7
	12H	24.3	25.5	24.7	25.9	26.3	26.8	28.0	27.2	28.3	28.8
4H	2H	22.8	24.2	23.2	24.5	24.9	23.9	25.3	24.3	25.6	26.0
	3H	24.5	25.7	24.9	26.1	26.5	26.3	27.5	26.7	27.9	28.3
	4H	25.1	26.2	25.5	26.6	27.0	27.1	28.2	27.5	28.6	29.0
	6H	25.6	26.5	26.1	27.0	27.4	27.7	28.6	28.1	29.0	29.5
	8H	25.8	26.6	26.2	27.1	27.5	27.8	28.7	28.3	29.1	29.6
	12H	25.8	26.6	26.3	27.1	27.6	27.9	28.7	28.4	29.2	29.7
8H	4H	25.7	26.6	26.2	27.0	27.5	27.4	28.3	27.9	28.7	29.2
	6H	26.4	27.1	26.9	27.6	28.1	28.1	28.8	28.6	29.3	29.8
	8H	26.6	27.3	27.1	27.8	28.3	28.3	29.0	28.8	29.5	30.0
	12H	26.8	27.4	27.3	27.9	28.4	28.5	29.1	29.0	29.6	30.1
12H	4H	25.8	26.6	26.3	27.1	27.5	27.4	28.2	27.9	28.7	29.1
	6H	26.5	27.2	27.0	27.6	28.2	28.1	28.8	28.7	29.3	29.8
	8H	26.8	27.4	27.3	27.9	28.4	28.4	29.0	28.9	29.5	30.1

Maximum UGR = 30.1

POLAR GRAPH



Maximum Candela = 10473.776 Located At Horizontal Angle = 90, Vertical Angle = .5
1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (.5) (Through Max. Cd.)