



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 14 SEL(20W) UV FR 8SEL(4000K).IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] Nick

[TESTLAB] Ningbo TengLi Testing Co., Ltd

[TESTDATE] 25 October 2019

[ISSUEDATE] 2019-10-25 14:51:21

[NEARFIELD]

[LAMPPOSITION] 0,0

[OTHER] EVERFINE GO-R5000\_V2 SYSTEM

[MANUFAC] LumenFocus, LLC.

[LUMINAIRE] FPB 14 SEL(20W) UV FR 8SEL(4000K)

[OTHER]

[OTHER]	Gamma(deg)	Fz(lm)	Ft(lm)	%Lum	%Lamp
---------	------------	--------	--------	------	-------

[OTHER]	0- 10	118.06	118.06	3.20	3.20
---------	-------	--------	--------	------	------

[OTHER]	10- 20	339.44	457.51	12.39	12.39
---------	--------	--------	--------	-------	-------

[OTHER]	20- 30	517.91	975.41	26.43	26.43
---------	--------	--------	--------	-------	-------

[OTHER]	30- 40	629.66	1605.07	43.48	43.48
---------	--------	--------	---------	-------	-------

[OTHER]	40- 50	658.94	2264.01	61.34	61.34
---------	--------	--------	---------	-------	-------

[OTHER]	50- 60	601.01	2865.01	77.62	77.62
---------	--------	--------	---------	-------	-------

[OTHER]	60- 70	464.82	3329.83	90.21	90.21
---------	--------	--------	---------	-------	-------

[OTHER]	70- 80	276.39	3606.22	97.70	97.70
---------	--------	--------	---------	-------	-------

[OTHER]	80- 90	81.25	3687.47	99.90	99.90
---------	--------	-------	---------	-------	-------

[OTHER]	90-100	0.41	3687.87	99.91	99.91
---------	--------	------	---------	-------	-------

[OTHER]	100-110	0.39	3688.26	99.92	99.92
---------	---------	------	---------	-------	-------

[OTHER]	110-120	0.48	3688.74	99.94	99.94
---------	---------	------	---------	-------	-------

[OTHER]	120-130	0.47	3689.21	99.95	99.95
---------	---------	------	---------	-------	-------

[OTHER]	130-140	0.52	3689.72	99.96	99.96
---------	---------	------	---------	-------	-------

[OTHER]	140-150	0.50	3690.23	99.98	99.98
---------	---------	------	---------	-------	-------

[OTHER]	150-160	0.44	3690.66	99.99	99.99
---------	---------	------	---------	-------	-------

[OTHER]	160-170	0.32	3690.99	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]	170-180	0.12	3691.11	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(20W) UV FR 8SEL(4000K).IES**

**CHARACTERISTICS**

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2546
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	127
Total Luminaire Watts	20
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.28
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.95 ft
Luminous Width (90-270)	0.95 ft
Luminous Height	0.00 ft

**LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2352	2404	2374
55	2270	2332	2301
65	2135	2201	2180
75	1903	1975	1982
85	1397	1541	1679

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(20W) UV FR 8SEL(4000K).IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	315.58	N.A.	12.40
0-30	672.82	N.A.	26.40
0-40	1107.15	N.A.	43.50
0-60	1976.25	N.A.	77.60
0-80	2487.52	N.A.	97.70
0-90	2543.56	N.A.	99.90
10-90	2462.12	N.A.	96.70
20-40	791.57	N.A.	31.10
20-50	1246.1	N.A.	48.90
40-70	1189.72	N.A.	46.70
60-80	511.27	N.A.	20.10
70-80	190.65	N.A.	7.50
80-90	56.04	N.A.	2.20
90-110	0.55	N.A.	0.00
90-120	0.88	N.A.	0.00
90-130	1.20	N.A.	0.00
90-150	1.90	N.A.	0.10
90-180	2.51	N.A.	0.10
110-180	1.97	N.A.	0.10
0-180	2546.07	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	81.44
10-20	234.14
20-30	357.24
30-40	434.33
40-50	454.53
50-60	414.57
60-70	320.62
70-80	190.65
80-90	56.04
90-100	0.28
100-110	0.27
110-120	0.33
120-130	0.32
130-140	0.36
140-150	0.35
150-160	0.30
160-170	0.22
170-180	0.08

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 14 SEL(20W) UV FR 8SEL(4000K).IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	103	99	95	106	101	97	94	97	94	91	93	90	88	89	87	85	83
2	98	90	83	77	96	88	82	76	84	79	74	81	77	73	78	74	71	69
3	90	79	70	64	87	77	69	63	74	67	62	71	66	61	69	64	60	58
4	82	70	61	54	80	68	60	53	66	58	53	63	57	52	61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	35	63	50	41	35	48	41	35	47	40	35	45	39	35	32
8	60	46	38	32	58	45	37	31	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	26	37	30	25	36	30	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(20W) UV FR 8SEL(4000K).IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	15.0	16.7	15.4	17.0	17.3	15.1	16.8	15.5	17.1	17.4
	3H	16.9	18.4	17.2	18.7	19.1	17.0	18.5	17.4	18.8	19.2
	4H	17.5	19.0	17.9	19.3	19.7	17.7	19.1	18.1	19.5	19.9
	6H	18.1	19.4	18.5	19.8	20.1	18.3	19.6	18.7	20.0	20.3
	8H	18.2	19.5	18.7	19.9	20.3	18.5	19.7	18.9	20.1	20.5
	12H	18.3	19.5	18.8	19.9	20.4	18.6	19.8	19.0	20.2	20.6
4H	2H	15.7	17.1	16.1	17.5	17.8	15.8	17.2	16.2	17.6	18.0
	3H	17.8	19.0	18.2	19.4	19.8	17.9	19.1	18.3	19.5	19.9
	4H	18.6	19.7	19.0	20.1	20.5	18.8	19.8	19.2	20.3	20.7
	6H	19.2	20.2	19.7	20.6	21.1	19.5	20.4	19.9	20.8	21.3
	8H	19.4	20.3	19.9	20.8	21.2	19.7	20.6	20.1	21.0	21.5
	12H	19.6	20.4	20.1	20.9	21.3	19.9	20.7	20.3	21.2	21.6
8H	4H	18.9	19.8	19.4	20.3	20.7	19.1	20.0	19.6	20.4	20.9
	6H	19.7	20.4	20.2	20.9	21.4	19.9	20.7	20.4	21.2	21.6
	8H	20.0	20.6	20.5	21.2	21.6	20.3	20.9	20.8	21.4	21.9
	12H	20.2	20.8	20.7	21.3	21.8	20.5	21.1	21.0	21.6	22.2
12H	4H	19.0	19.8	19.4	20.2	20.7	19.2	20.0	19.6	20.4	20.9
	6H	19.8	20.4	20.3	20.9	21.4	20.0	20.7	20.6	21.2	21.7
	8H	20.1	20.7	20.6	21.2	21.7	20.4	21.0	20.9	21.5	22.0

Maximum UGR = 22.2

POLAR GRAPH



Maximum Candela = 860.046 Located At Horizontal Angle = 90, Vertical Angle = 1  
# 1 - Vertical Plane Through Horizontal Angles (90 - 270) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)