



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 14 SEL(40W) UV FR 8SEL(3500K).IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] Nick

[TESTLAB] Ningbo TengLi Testing Co., Ltd

[TESTDATE] 14 October 2019

[ISSUEDATE] 2019-10-14 10:59:43

[NEARFIELD]

[LAMPPOSITION] 0,0

[OTHER] EVERFINE GO-R5000\_V2 SYSTEM

[MANUFAC] LumenFocus, LLC.

[LUMINAIRE] FPB 14 SEL(40W) UV FR 8SEL(3500K)

[OTHER]

[OTHER]	Gamma(deg)	Fz(lm)	Ft(lm)	%Lum	%Lamp
---------	------------	--------	--------	------	-------

[OTHER]	0- 10	116.10	116.10	3.21	3.21
---------	-------	--------	--------	------	------

[OTHER]	10- 20	333.86	449.95	12.45	12.45
---------	--------	--------	--------	-------	-------

[OTHER]	20- 30	509.57	959.53	26.54	26.54
---------	--------	--------	--------	-------	-------

[OTHER]	30- 40	619.93	1579.46	43.69	43.69
---------	--------	--------	---------	-------	-------

[OTHER]	40- 50	648.99	2228.44	61.65	61.65
---------	--------	--------	---------	-------	-------

[OTHER]	50- 60	591.00	2819.44	78.00	78.00
---------	--------	--------	---------	-------	-------

[OTHER]	60- 70	453.29	3272.73	90.54	90.54
---------	--------	--------	---------	-------	-------

[OTHER]	70- 80	263.11	3535.84	97.81	97.81
---------	--------	--------	---------	-------	-------

[OTHER]	80- 90	74.65	3610.49	99.88	99.88
---------	--------	-------	---------	-------	-------

[OTHER]	90-100	0.70	3611.20	99.90	99.90
---------	--------	------	---------	-------	-------

[OTHER]	100-110	0.50	3611.70	99.91	99.91
---------	---------	------	---------	-------	-------

[OTHER]	110-120	0.58	3612.28	99.93	99.93
---------	---------	------	---------	-------	-------

[OTHER]	120-130	0.55	3612.83	99.94	99.94
---------	---------	------	---------	-------	-------

[OTHER]	130-140	0.58	3613.40	99.96	99.96
---------	---------	------	---------	-------	-------

[OTHER]	140-150	0.54	3613.95	99.97	99.97
---------	---------	------	---------	-------	-------

[OTHER]	150-160	0.46	3614.41	99.99	99.99
---------	---------	------	---------	-------	-------

[OTHER]	160-170	0.33	3614.74	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]	170-180	0.13	3614.87	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(40W) UV FR 8SEL(3500K).IES**

**CHARACTERISTICS**

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4988
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	125
Total Luminaire Watts	40
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.28
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.42
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	3.95 ft
Luminous Width (90-270)	0.95 ft
Luminous Height	0.00 ft

**LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	4626	4733	4697
55	4456	4585	4559
65	4163	4295	4298
75	3647	3792	3809
85	2638	2957	3149

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(40W) UV FR 8SEL(3500K).IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	620.85	N.A.	12.40
0-30	1323.96	N.A.	26.50
0-40	2179.34	N.A.	43.70
0-60	3890.28	N.A.	78.00
0-80	4878.77	N.A.	97.80
0-90	4981.78	N.A.	99.90
10-90	4821.59	N.A.	96.70
20-40	1558.49	N.A.	31.20
20-50	2453.97	N.A.	49.20
40-70	2336.38	N.A.	46.80
60-80	988.50	N.A.	19.80
70-80	363.04	N.A.	7.30
80-90	103.01	N.A.	2.10
90-110	1.66	N.A.	0.00
90-120	2.46	N.A.	0.00
90-130	3.22	N.A.	0.10
90-150	4.77	N.A.	0.10
90-180	6.03	N.A.	0.10
110-180	4.37	N.A.	0.10
0-180	4987.81	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	160.19
10-20	460.66
20-30	703.11
30-40	855.39
40-50	895.47
50-60	815.46
60-70	625.45
70-80	363.04
80-90	103.01
90-100	0.97
100-110	0.69
110-120	0.81
120-130	0.76
130-140	0.79
140-150	0.75
150-160	0.63
160-170	0.46
170-180	0.17

# IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 14 SEL(40W) UV FR 8SEL(3500K).IES

## COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	108	104	99	95	106	101	97	94	97	94	91	93	90	88	89	87	85	83
2	98	90	83	77	96	88	82	76	85	79	75	81	77	73	78	74	71	69
3	90	79	71	64	87	77	70	63	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	64	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	45	42
6	69	56	47	40	68	55	46	40	53	46	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	46	37	32	44	37	31	43	36	31	42	36	31	29
9	56	42	34	29	55	42	34	28	41	33	28	40	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	38	30	26	37	30	25	36	30	25	24


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : FPB 14 SEL(40W) UV FR 8SEL(3500K).IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	17.3	19.0	17.7	19.3	19.6	17.5	19.2	17.9	19.5	19.8
	3H	19.1	20.6	19.5	21.0	21.3	19.3	20.8	19.7	21.2	21.5
	4H	19.8	21.2	20.2	21.6	21.9	20.0	21.5	20.4	21.8	22.2
	6H	20.3	21.6	20.7	22.0	22.4	20.6	21.9	21.0	22.2	22.6
	8H	20.4	21.7	20.9	22.1	22.5	20.7	22.0	21.1	22.4	22.8
	12H	20.5	21.7	21.0	22.1	22.6	20.8	22.1	21.3	22.4	22.9
4H	2H	18.0	19.4	18.4	19.8	20.1	18.2	19.6	18.6	19.9	20.3
	3H	20.0	21.2	20.4	21.6	22.0	20.3	21.4	20.7	21.8	22.2
	4H	20.8	21.9	21.2	22.3	22.7	21.1	22.1	21.5	22.6	23.0
	6H	21.4	22.4	21.9	22.8	23.3	21.7	22.7	22.2	23.1	23.6
	8H	21.6	22.5	22.1	23.0	23.4	21.9	22.8	22.4	23.3	23.7
	12H	21.8	22.6	22.3	23.0	23.5	22.1	22.9	22.6	23.4	23.8
8H	4H	21.1	22.0	21.6	22.5	22.9	21.4	22.3	21.9	22.7	23.2
	6H	21.9	22.6	22.4	23.1	23.6	22.2	22.9	22.7	23.4	23.9
	8H	22.1	22.8	22.6	23.3	23.8	22.5	23.1	23.0	23.7	24.1
	12H	22.4	22.9	22.9	23.4	24.0	22.7	23.3	23.2	23.8	24.4
12H	4H	21.2	22.0	21.7	22.4	22.9	21.5	22.2	21.9	22.7	23.2
	6H	21.9	22.6	22.5	23.1	23.6	22.3	22.9	22.8	23.4	23.9
	8H	22.3	22.8	22.8	23.3	23.9	22.6	23.2	23.1	23.7	24.3

Maximum UGR = 24.4

POLAR GRAPH



Maximum Candela = 1692.305 Located At Horizontal Angle = 135, Vertical Angle = 1  
# 1 - Vertical Plane Through Horizontal Angles (135 - 315) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)