



IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 22 SEL(30W) UV FR 8SEL(5000K).IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] Nick

[TESTLAB] Ningbo TengLi Testing Co., Ltd

[TESTDATE] 26 December 2019

[ISSUEDATE] 2019-12-26 15:12:52

[NEARFIELD]

[LAMPPOSITION] 0,0

[OTHER] EVERFINE GO-R5000_V2 SYSTEM

[MANUFAC] LumenFocus, LLC.

[LUMINAIRE] FPB 22 SEL(30W) UV FR 8SEL(5000K)

[OTHER]

[OTHER]	Gamma(deg)	Fz(lm)	Ft(lm)	%Lum	%Lamp
---------	------------	--------	--------	------	-------

[OTHER]	0- 10	126.38	126.38	3.26	3.26
---------	-------	--------	--------	------	------

[OTHER]	10- 20	362.37	488.75	12.60	12.60
---------	--------	--------	--------	-------	-------

[OTHER]	20- 30	550.36	1039.11	26.79	26.79
---------	--------	--------	---------	-------	-------

[OTHER]	30- 40	665.64	1704.75	43.96	43.96
---------	--------	--------	---------	-------	-------

[OTHER]	40- 50	693.24	2397.99	61.83	61.83
---------	--------	--------	---------	-------	-------

[OTHER]	50- 60	629.47	3027.46	78.06	78.06
---------	--------	--------	---------	-------	-------

[OTHER]	60- 70	484.52	3511.97	90.55	90.55
---------	--------	--------	---------	-------	-------

[OTHER]	70- 80	284.95	3796.92	97.90	97.90
---------	--------	--------	---------	-------	-------

[OTHER]	80- 90	77.35	3874.27	99.89	99.89
---------	--------	-------	---------	-------	-------

[OTHER]	90-100	0.90	3875.17	99.92	99.92
---------	--------	------	---------	-------	-------

[OTHER]	100-110	0.24	3875.41	99.92	99.92
---------	---------	------	---------	-------	-------

[OTHER]	110-120	0.49	3875.90	99.94	99.94
---------	---------	------	---------	-------	-------

[OTHER]	120-130	0.61	3876.51	99.95	99.95
---------	---------	------	---------	-------	-------

[OTHER]	130-140	0.62	3877.14	99.97	99.97
---------	---------	------	---------	-------	-------

[OTHER]	140-150	0.50	3877.64	99.98	99.98
---------	---------	------	---------	-------	-------

[OTHER]	150-160	0.37	3878.01	99.99	99.99
---------	---------	------	---------	-------	-------

[OTHER]	160-170	0.27	3878.29	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]	170-180	0.10	3878.39	100.00	100.00
---------	---------	------	---------	--------	--------

[OTHER]

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FPB 22 SEL(30W) UV FR 8SEL(5000K).IES

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	3878
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	127
Total Luminaire Watts	30.5
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.40
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	1.95 ft
Luminous Width (90-270)	1.95 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	3534	3574	3633
55	3393	3444	3527
65	3162	3234	3354
75	2776	2886	3061
85	1892	2000	2321

IES INDOOR REPORT
PHOTOMETRIC FILENAME : FPB 22 SEL(30W) UV FR 8SEL(5000K).IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	488.75	N.A.	12.60
0-30	1039.11	N.A.	26.80
0-40	1704.75	N.A.	44.00
0-60	3027.46	N.A.	78.10
0-80	3796.92	N.A.	97.90
0-90	3874.27	N.A.	99.90
10-90	3747.89	N.A.	96.60
20-40	1215.99	N.A.	31.40
20-50	1909.23	N.A.	49.20
40-70	1807.22	N.A.	46.60
60-80	769.46	N.A.	19.80
70-80	284.95	N.A.	7.30
80-90	77.35	N.A.	2.00
90-110	1.14	N.A.	0.00
90-120	1.63	N.A.	0.00
90-130	2.24	N.A.	0.10
90-150	3.37	N.A.	0.10
90-180	4.12	N.A.	0.10
110-180	2.98	N.A.	0.10
0-180	3878.39	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	126.38
10-20	362.37
20-30	550.36
30-40	665.64
40-50	693.24
50-60	629.47
60-70	484.52
70-80	284.95
80-90	77.35
90-100	0.90
100-110	0.24
110-120	0.49
120-130	0.61
130-140	0.62
140-150	0.50
150-160	0.37
160-170	0.27
170-180	0.10

IES INDOOR REPORT

PHOTOMETRIC FILENAME : FPB 22 SEL(30W) UV FR 8SEL(5000K).IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	97	94	97	94	91	93	90	88	90	87	85	83
2	99	90	83	77	96	88	82	76	85	79	75	81	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	69	60	54	66	59	53	64	57	52	61	56	52	49
5	75	62	53	47	73	61	53	46	59	52	46	57	50	45	55	49	45	43
6	70	56	47	41	68	55	47	40	53	46	40	52	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	48	41	35	47	40	35	46	39	35	33
8	60	46	38	32	58	46	37	32	44	37	32	43	36	31	42	36	31	29
9	56	43	34	29	55	42	34	29	41	33	28	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24


IES INDOOR REPORT
PHOTOMETRIC FILENAME : FPB 22 SEL(30W) UV FR 8SEL(5000K).IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	16.3	18.0	16.7	18.3	18.6	16.6	18.2	16.9	18.5	18.9
	3H	18.1	19.6	18.5	19.9	20.3	18.4	20.0	18.8	20.3	20.6
	4H	18.8	20.2	19.2	20.6	20.9	19.2	20.6	19.6	20.9	21.3
	6H	19.3	20.6	19.7	21.0	21.4	19.7	21.0	20.1	21.4	21.8
	8H	19.5	20.7	19.9	21.1	21.5	19.9	21.2	20.3	21.5	21.9
	12H	19.5	20.7	20.0	21.1	21.5	20.0	21.2	20.4	21.6	22.0
4H	2H	17.0	18.4	17.4	18.7	19.1	17.2	18.6	17.6	19.0	19.3
	3H	19.0	20.2	19.4	20.6	21.0	19.3	20.5	19.7	20.9	21.3
	4H	19.8	20.9	20.2	21.3	21.7	20.2	21.3	20.6	21.7	22.1
	6H	20.4	21.4	20.9	21.8	22.3	20.9	21.8	21.3	22.2	22.7
	8H	20.6	21.5	21.1	22.0	22.4	21.1	22.0	21.6	22.4	22.9
	12H	20.8	21.6	21.2	22.0	22.5	21.3	22.0	21.7	22.5	23.0
8H	4H	20.2	21.0	20.6	21.5	21.9	20.5	21.4	21.0	21.8	22.3
	6H	20.9	21.6	21.4	22.1	22.6	21.3	22.1	21.8	22.5	23.0
	8H	21.1	21.8	21.7	22.3	22.8	21.6	22.3	22.1	22.8	23.3
	12H	21.3	21.9	21.8	22.4	23.0	21.9	22.4	22.4	22.9	23.5
12H	4H	20.2	21.0	20.7	21.5	21.9	20.6	21.3	21.0	21.8	22.3
	6H	21.0	21.6	21.5	22.1	22.6	21.4	22.1	21.9	22.5	23.1
	8H	21.3	21.8	21.8	22.3	22.9	21.7	22.3	22.3	22.8	23.4

Maximum UGR = 23.5

POLAR GRAPH



Maximum Candela = 1335.43 Located At Horizontal Angle = 180, Vertical Angle = 1
1 - Vertical Plane Through Horizontal Angles (180 - 0) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (1) (Through Max. Cd.)